

## CERTIFICATE OF CONFORMITY

**Producer**

**VARIANT plus, spol. s r.o.**, U Oburky 5, 674 01 Trebic, CZECH REPUBLIC  
IČO: 46967168, DIČ CZ-46967168

**Product**

Smoke Detector

**Product  
Indication**

**VAR-TEC FDR-26-S**

**Usage**

Product is used as the additional detection of smoke developed by fire for intruder alarm systems.

**Declaration**

We declare that according to tests reports mentioned below the properties of products correspond to the technical requirements for such kind of products. We confirm the product is safe under conditions mentioned in technical documentation.

---

### The Product was tested under the following standards

**Test Protocol**

0845 – CPD – 232.1437

Issued by Certified Laboratory of Danish Institute of Fire and Security Technology, Notified body No. 0845

The Products corresponds to the standard **EN54-7:2000** only in case when it is wired into the loop of central alarm panel and this connection strictly determines which smoke detector indicated an alarm.

The Product also corresponds to the European standards  
EN 61000-6-3 : 2001, EN 50130-4 : 1995

Issued in Trebic, October 10, 2008

